QUALITY CONTROL ABSTRACT (AS PER MORT&H-V REVISION)

Name of Work: Developments works to be under taken in Ward No.05 of BBMP around Solid Waste Disposal Processing units Bellahalli, Bagaluru and Kattigenahalli Byatarayanapura Constituency

Name of Agency :- Sri.A G. Narayana Swamy.

Bill: Second and Part Bill

Sl No	Description of Items	Test	Test Units	Test Per Qty	Up to Date Qty	Convertion m^3 > m^2	Convertion m^3 > Tonnes	No. Of Sample to Be Conduct for Test	No of Sample Conducted for Test
	For Road Work								
1	Granular Sub-Base (GSB)								
		Gradation	m^3	400.00	2300.52	-	-	6	4
		Density of Compacted Layer	m^2	1000.00	2300.52	11502.60	-	12	6
2	Wet Mix Macadam(WMM)								
		Aggrgate impact Value(AIV)	m^3	1000.00	6295.57	-	-	6	3
		Combained Flakiness & Elonga	m^3	500.00	6295.57	-	-	13	5
		Gradation	m^3	400.00	6295.57	-	-	16	5
		Density of Compacted Layer	m^2	1000.00	6295.57	25182.28	-	25	8

TEJU & CONSULTANTS

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Consultant